



BUREAU
VERITAS

Industry Division



CERTIFICADO DE APTITUD TÉCNICA

Nº BVA / SCI / 118 - 25

Trámite: Renovación

Se certifica a:

MELISAM S.A.

Los Ceibos 428 (1609) - Boulogne
San Isidro - Prov. Buenos Aires - R. Argentina

Producto:

SISTEMA FIJO DE EXTINCIÓN DE INCENDIO CON AGENTES LIMPIOS

Marca:

MELISAM

Datos Generales

Representante Técnico:	ING. JOSE VAZQUEZ ALVAREZ
Matrícula Profesional Nº:	24320
Matrícula Nº:	SCI 0352

Caraterísticas Técnicas

Material del recipiente:	chapa laminada IRAM IAS U 500-231	Espesor de chapa:	3,2 a 4,72 mm
Agente extintor:	heptafluoropropano (HFC227ea)	Presión de Trabajo:	25 bar a 20°C
Campo de Aplicación:	Extinción de Incendios	Válvulas de accionamiento:	ROTAREX
Accionamiento:	Automático y/o manual	Medio de Aplicación:	por medio de difusores
Marcado:	Fecha de fabricación; Nº de cilindro; Presión de Prueba; Marca o Fabricante; Identificación "MFG"		

El Fabricante conjuntamente con el Representante Técnico, serán responsables por los daños y perjuicios provenientes de accidentes que ocurran por deficiencia en los procesos de fabricación. El almacenamiento del producto terminado se deberá realizar sin excepción dentro de la planta donde fue producido hasta el momento de su comercialización. La utilización de depósitos o almacenes externos deberá ser puesta a consideración de Bureau Veritas Argentina S.A. para su posterior evaluación y aprobación. Previo a toda modificación, variación o alteración a realizar sobre las instalaciones, equipamientos y documentación que originan el presente certificado, se deberá notificar formalmente a Bureau Veritas Argentina S.A. para su consideración, evaluación y aprobación. EL INCUMPLIMIENTO DE ESTE REQUISITO INVALIDARÁ EL PRESENTE CERTIFICADO.

Bureau Veritas Argentina S.A. solamente certifica que las muestras y documentación técnica de los elementos presentados se ajustan a la especificación técnica, siendo responsabilidad del Fabricante su ejecución de acuerdo al modelo certificado y deslinda toda responsabilidad por los daños y perjuicios que pudieran producirse por fallas o defectos de materia prima, fabricación o ensayos.

La utilización de este tipo de agente extintor puede provocar daños severos para la salud, los usuarios durante la manipulación del agente deben cumplir con las especificaciones de seguridad descriptas por el fabricante. Todas las personas deben evacuar el recinto en caso de accionamiento.

La validez de este certificado caduca en forma automática, sin necesidad de una previa notificación formal por parte de este Organismo de Certificación, en el caso de vencimiento y/o suspensión de Habilitaciones o incumplimiento de disposiciones legales vigentes del lugar en que se encuentra ubicada la empresa.

Esta Licencia, es válida hasta el:

15 de Enero de 2026

Emitido en

Buenos Aires, 16 de Enero de 2025

ING. LUCAS FERNANDO BUSO
GERENTE DE DIVISIÓN
SEGURIDAD CONTRA INCENDIOS

Este certificado es expedido de acuerdo a los Términos y Condiciones Generales de Servicio de Bureau Veritas (Revisión 2011 A).

Verifique vigencia y validez de este certificado, escaneando el código QR o llamando al tel. (54-11) 4000-8008.



BUREAU
VERITAS

Industry Division



CERTIFICATE OF TECHNICAL APTITUDE

N° BVA / SCI / 118 - 25

Procedure: Approval

This certifies to:

MELISAM S.A.

Los Ceibos 428 (1609) - Boulogne
San Isidro - Prov. Buenos Aires - R. Argentina

Product:

FIXED FIRE EXTINGUISHING SYSTEM WITH CLEAN AGENTS

Brand:

MELISAM

General information

Technical Representative:	ENG. JOSE VAZQUEZ ALVAREZ
Professional Registration:	24320
Product Registration:	SCI 0352

Technical features

Cylinder material:	Laminated sheet IRAM IAS U 500-231	Sheet thickness:	3.2 to 4.72 mm
Extinguishing agent:	heptafluoropropane (HFC227ea)	Working Pressure:	25 bar at 20°C
Field of Application:	Fire Fighting	Actuating valves:	ROTAREX
Activation:	Automatic and/or manual	Means of Application:	by means of diffusers
Marking:	Date of manufacture; cylinder no.; test pressure; Brand or Manufacturer; "MFG" identification		

The use of this type of extinguishing agent can cause severe damage to health, users while handling the agent must comply with the safety specifications described by the manufacturer. All people must evacuate the premises in case the system is activated. The Manufacturer, together with the Technical Representative, will be responsible for the damages and losses resulting from accidents that occur due to deficiencies in the manufacturing processes. The storage of the finished product must be carried out without exception within the plant where it was produced until the moment of its manufacture, commercialization. The use of external deposits or warehouses must be put to the consideration of Bureau Veritas Argentina S.A. for further evaluation and approval. Prior to any modification, variation or alteration to be made to the facilities, equipment and documentation that originate this certificate, Bureau Veritas Argentina S.A. must be formally notified, for your consideration, evaluation and approval. FAILURE TO COMPLY WITH THIS REQUIREMENT WILL INVALIDATE THIS CERTIFICATE.

Bureau Veritas Argentina S.A. it only certifies that the samples and technical documentation of the elements presented conform to the technical specification, the Manufacturer being responsible for its execution according to the certified model and disclaims all responsibility for damages that may occur due to failures or defects of raw material, manufacturing or testing.

The validity of this certificate expires automatically, without the need for prior formal notification by this Certification Body, in the event of expiration and/or suspension of Qualifications and non-compliance with current legal provisions of the place where the facility is located, business.

This license is valid until:

January 15th, 2026

At / on

Buenos Aires, January 16th, 2025

ENG. LUCAS FERNANDO BUSO
DIVISION MANAGER
FIRE SAFETY

This certificate is issued in accordance with the General Terms and Conditions of Service of Bureau Veritas (Revision 2011 A).
Verify validity and validity of this certificate, scanning the QR code or calling tel. (54-11) 4000-8008.